

# WEST JORDAN FIRE DEPARTMENT FIRE INSPECTION CHECKLIST

7602 S. Jordan Landing Blvd.  
West Jordan, Utah 84084  
Office (801) 260-7300 Fax (801) 260-7320

## ADDRESS

<input type="checkbox"/>	Property address posted on street side of building	IFC2006 505.1
<input type="checkbox"/>	Fire department access to within 150' of any part of the building	IFC2006 503.1

## ELECTRICAL

<input type="checkbox"/>	Electrical boxes, outlets and switches properly covered	IFC2006 605.6
<input type="checkbox"/>	Electrical panels properly covered and latched	IFC2006 605.6
<input type="checkbox"/>	Electrical panel accessible (min. 30" width, 78" height, 36" in depth)	IFC2006 605.3
<input type="checkbox"/>	Extension cords: temporary use only, not through walls, ceilings or under doors	IFC2006 605.5
<input type="checkbox"/>	Electrical multi-plug adapters: approved internal circuit breaker type only and plugged directly to permanent receptacle	IFC2006 605.4.1

## EXITS

<input type="checkbox"/>	Exterior doors are readily accessible	IFC2006 504.1
<input type="checkbox"/>	Exit doors unlocked during business hours	IFC2006 1008.1.8.3
<input type="checkbox"/>	Exit ways free from obstructions	IFC2006 1015.2
<input type="checkbox"/>	Exit signs present at required exits (6" letters)	IFC2006 1011.5.1
<input type="checkbox"/>	Lighted exit signs operating properly	IFC2006 1011.5.2
<input type="checkbox"/>	No storage under unprotected exit stairways	IFC2006 315.2.4
<input type="checkbox"/>	Means of egress must be continuous and cannot be blocked	IFC2006 1003.6
<input type="checkbox"/>	Sufficient egress to meet occupant load is required (Table 1005.1)	IFC2006 1005.1

## EXTINGUISHERS

<input type="checkbox"/>	Minimum size 2A10BC extinguisher	IFC2006 906.2
<input type="checkbox"/>	Current State Fire Marshal approved inspection tag	IFC2006 901.6.1
<input type="checkbox"/>	Properly mounted and accessible (height not < 4", nor > 5')	IFC2006 906.9
<input type="checkbox"/>	Correct number, type and size for the use or occupancy	IFC2006 906.3
<input type="checkbox"/>	Dry chemical suppression systems inspected every 6 months	IFC2006 904.6
<input type="checkbox"/>	Wet chemical suppression systems inspected every 6 months	IFC2006 904.5

## HOUSEKEEPING

<input type="checkbox"/>	Dispose of combustible waste	IFC2006 304.1
<input type="checkbox"/>	Exterior free of litter and weeds	IFC2006 304.1.1
<input type="checkbox"/>	Oily rags stored in approved containers	IFC2006 304.3.1

## MECHANICAL

<input type="checkbox"/>	No combustibles stored in furnace or boiler room	IFC2006 315.2.3
<input type="checkbox"/>	Furnace, boiler, water heater, etc. are vented to prevent a fire hazard	IFC2006 603.6
<input type="checkbox"/>	Gas meter protected and accessible	IFC2006 603.9

## SMOKING

<input type="checkbox"/>	Prohibited in warehouse storage areas, other hazardous areas	IFC2006 310.1
--------------------------	--	---------------

## ALARM and SPRINKLER SYSTEMS (WHERE REQUIRED)

<input type="checkbox"/>	Fire and life safety systems are maintained in an operable condition	IFC2006 907.20.5
<input type="checkbox"/>	Sprinkler shut off readily accessible	IFC2006 508.5.4
<input type="checkbox"/>	All storage 18" below sprinkler head level	IFC2006 315.2.1
<input type="checkbox"/>	Sprinkler systems shall be inspected and tagged annually	IFC2006 901.6.1

## STORAGE

<input type="checkbox"/>	All flammable and combustible liquids to be stored properly	IFC2006 3404.3
<input type="checkbox"/>	Compressed gas cylinders must be secured from falling	IFC2006 3003.5.3
<input type="checkbox"/>	No combustible storage in unprotected attics or crawl spaces	IFC2006 315.2.4
<input type="checkbox"/>	Storage maintained 2' below the ceiling in non-sprinkler protected areas	IFC2006 315.2.1

## STRUCTURES

<input type="checkbox"/>	Required fire separation intact	IFC2006 703
--------------------------	---------------------------------	-------------